

COUNTY OF ROCKLAND  
Department of General Services  
Purchasing Division

# Contract Award Notification

Title: **Sludge Collection Equipment- Replacement Parts**

Contract Period: October 27, 2025 through October 26, 2026 w/ (4) 1-year options

Original Date of Issue: 10/27/25

Date of Revision:

**BID No:** **RFB-RC-2025-106**

**Catalog:** **Wastewater**

Authorized Users: United States Agencies, Other States & Political Subdivisions Therein,  
Local Governments, School Districts & Non-Profit Agencies

Address Inquiries To:

Name: Michele Phillips  
Title: Purchaser II  
Phone: 845-364-2984  
Fax: 845-364-3809  
E-mail: [phillipm@co.rockland.ny.us](mailto:phillipm@co.rockland.ny.us)

**Description**

This contract is to purchase of specified replacement parts for the RCSD #1 primary and secondary settling tanks (A and B Sides) at the RCSD # 1 treatment plant.

Contract #	Vendor Number	Contractor & Address	Telephone No.
BID 25-106	0000012818	Applied Industrial Technologies 6 Enterprise Drive Albany, NY 12204 Contact: Mark Spink <a href="mailto:2341@applied.com">2341@applied.com</a>	518-427-5800
BID 25-106-A	0000022858	Eastern Industrial Automation 14 Sebago Street Clifton, NJ 07013 Contact: Tom Dunch <a href="mailto:Tdunch@easternia.com">Tdunch@easternia.com</a>	781-899-3952 Ext 1102
BID 25-106-B	0000023044	GP Jager Inc. PO Box 739512 Dallas, TX 75373 Contact: Gregory P. Jager <a href="mailto:jsanz@jagerinc.com">jsanz@jagerinc.com</a>	973-750-1180

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
<b>Sprockets are to be deep chilled with a Birnell  hardness of 360 min. and 3/16” minimum depth chill</b>									
#1-1	(A SIDE) Y16A bearing support and bearing for 2 7/16” dia. Shaft, Fairfield/FMC, Siemens Industry JK5111-16A, Brewton W3789 or approved equal	89065000003	4	Each	\$ 557.57	FAIRFIELD	BS-MS-2 7/16	8-10 weeks	GP JAGER
#1-2	(A SIDE) 117Y, 46-3 spiral jaw clutch, RH, WT-42, Brewton W4812-2, 95811 Fairfield or approved equal	89065000004	4	Each	\$ 759.37	FAIRFIELD	OBBIW-W4812-2	8-10 weeks	GP JAGER
#1-3	(A SIDE) 117Y, 46-4 spiral jaw clutch, LH, WT-43, Brewton W4812-2, 95811 Fairfield or approved equal	89065000005	4	Each	\$ 759.37	FAIRFIELD	OBBIW-W4812-2	8-10 weeks	GP JAGER
#1-4	(A SIDE) 358Y, 102-3 hand wheel, RH, WT-44, Brewton W4812-1, 95811 Fairfield or approved equal	89065000006	4	Each	\$ 724.45	FAIRFIELD	OBBIW-W4812-1	8-10 weeks	GP JAGER
#1-5	(A SIDE) 358Y, 102-4 hand wheel, LH, WT-45, Brewton W4812-2 Fairfield or approved equal	89065000007	4	Each	\$ 724.45	FAIRFIELD	OBBIW-W4812-2	8-10 weeks	GP JAGER
#1-6	(A SIDE) 496W95-A safety collars 2 7/16” dia. WT-51, Cut Sheet Brewton 95881 Fairfield or approved equal	89065000009	4	Each	\$ 99.00	FAIRFIELD	OBBIW-WT-51	8-10 weeks	GP JAGER
#1-7	(A SIDE) 158X11E tightener and sprocket for H78 chain WT-71, Brewton 2916-1, 95881 Fairfield or approved equal	89065000011	4	Each	\$ 955.15	FAIRFIELD	OBBIW-2916-1	8-10 weeks	GP JAGER
#1-8	(A SIDE) 158X11F tightener and sprocket for H78 chain WT-72, Brewton 2917-1, 95881 Fairfield or approved equal	89065000012	4	Each	\$ 955.15	FAIRFIELD	OBBIW-2917-1	8-10 weeks	GP JAGER
#1-9	(A SIDE) Y20-A driver sprocket, #H78, FR. 11T, 9.26” P.D. with shear pin hub, bronze bushed with sleeve and trip device for limit switch, bore for 1 7/8” shaft keys ½” x ¼”, stainless steel sleeve, Brewton W-4829 Fairfield or approved equal	89065000013	6	Each	\$ 1,872.07	FAIRFIELD	OBBIW-W-4829	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-10	(A SIDE) Cross collector sprocket (driven) Wt. 92, split sprocket, #H78, 12T, 10.08" P.D. HBS-L2-215, 5 1/4" x 3 5/8" TWC, bore 2.940 + .003, KS. SS. PATT.P P-42831, Brewton W4813, 95811 Fairfield or approved equal	89065000015	4	Each	\$ 561.00	FAIRFIELD	OBBIW-W4813	8-10 weeks	GP JAGER
#1-11	(A SIDE) 492Z115-A split, peak cap brgs babb. 2 15/16", WT-11, Brewton W3695, 95881 Fairfield or approved equal	89065000016	1	Each	\$ 599.28	FAIRFIELD	OBBIW-W3695	8-10 weeks	GP JAGER
#1-12	(A SIDE) 1571Z39-A split M.I. SAF. Collar 2 15/16", WT-12, Brewton 95881 Cut Sheets or approved equal	89065001017	1	Each	\$ 110.88	FAIRFIELD	OBBIW-WT-12	8-10 weeks	GP JAGER
#1-13	(A & B SIDES) 1101Y51-D split sprocket #H78, 40-T. 33.24"P.D. dished arms. Bore for 2 15/16" shaft, KS.S.S. for plastic chain, WT-13, Brewton W2834, 95881 Fairfield or approved equal	89065000018	1	Each	\$ 2,791.80	FAIRFIELD	OBBIW-W2834	8-10 weeks	GP JAGER
#1-14	(A & B SIDES) Collars 2 15/16", WT-12, Brewton 95881 Cut Sheets or approved equal	89065001019	1	Each	\$ 110.88	FAIRFIELD	OBBIW-WT-12	8-10 weeks	GP JAGER
#1-15	(A SIDE) 492Z131-K split sprockets #720-SC.F.R. 17-T, 8 1/2P. 16.61P.D. Bore for 2 15/16" SFT., S.S. for plastic chain, (4 3/4" TWC), WT-21, Brewton W4808, 95881, Fairfield or approved equal	89065000020	1	Each	\$ 848.10	FAIRFIELD	OBBIW-W4808	8-10 weeks	GP JAGER
#1-16	(A SIDE) JK3587-13-C take-up units with split peak cap brgs. babb. 2 15/16", WT-31, Brewton W3608, 95881 or approved equal	89065000021	1	Each	\$ 1,361.26	FAIRFIELD	OBBIW-WT31-W3608	8-10 weeks	GP JAGER
#1-17	(A SIDE) JK3587-13-D take up units with split peak cap brgs. babb. 2 15/16", WT-32, Brewton 3608, 95881 or approved equal	89065000022	1	Each	\$ 1,361.26	FAIRFIELD	OBBIW-WT32-W3608	8-10 weeks	GP JAGER
#1-18	(A SIDE) 1352Y28-K split sprockets #720-SC. 19-T, 9 1/2P., 18.48 P.D. Bore for 2 15/16" SFT.KS.IN line as pairs, S.S. for plastic chain (5/6 TWC), WT-14, Brewton W4412, 95881 Fairfield or approved equal	89065000023	1	Each	\$ 940.50	FAIRFIELD	OBBIW-W4412	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-19	(A SIDE) 492Z131-L split sprockets, #720-SC F.R., 17.T., 8 1/2P, 16.61 P.D. Bore for 2 15/16" SFT. Plain (NoS.S.) for plastic chain (4 3/4" TWC), WT-22, Brewton W4808, 95881, Fairfield or approved equal	89065000024	1	Each	\$ 848.10	FAIRFIELD	OBBIW-W4808	8-10 weeks	GP JAGER
#1-20	(A SIDE) Peak cap bearings. 2 15/16", WT-11, Brewton W3695, 95881 or approved equal	89065000025	1	Each	\$ 599.28	FAIRFIELD	OBBIW-WT11-W3695	8-10 weeks	GP JAGER
#1-21	(A SIDE) Collars 2 15/16", WT-12, Brewton 95881 or approved equal	89065001026	1	Each	\$ 110.88	FAIRFIELD	OBBIW-WT-12	8-10 weeks	GP JAGER
#1-22	(A SIDE) Split sprockets 17-T, #720.SC S.S, WT-21, Brewton W4808, 95881 or approved equal	89065000027	1	Each	\$ 848.76	FAIRFIELD	OBBIW-W4808	8-10 weeks	GP JAGER
#1-23	(A SIDE) Split sprockets 17-T, #720.SC plain, WT-22, Brewton W4809, 95881 or approved equal	89065000028	1	Each	\$ 825.00	FAIRFIELD	OBBIW-W4809	8-10 weeks	GP JAGER
#1-24	(A SIDE) Link Belt, Steady Rest Bearing – Part#2-1239Z, 2-7/16, Link Belt 2-1239Z, Brewton/Fairfield, or approved equal	89065000037	4	Each	\$ 825.00	FAIRFIELD	OBBIW-2-1239Z	8-10 weeks	GP JAGER
#1-25	(A & B SIDES) Right Hand Screw, 18" Diameter, 18" Pitch 3/8" Thick, Sectional flight welded on 5 1/2" SCH80 Pipe, Bushed and 2-Bolt drilled for 2-15/16" Shafts. Over All Length 9'8". James Eagen Sons, Charter Machine Company Charter Machine Company Part #: 18SQ624-R, Martin Sprocket or approved equal	89077000001	5	Each	\$ 3,013.56	FAIRFIELD	OBMS-18SQ624	8-10 weeks	GP JAGER
#1-26	(A & B SIDES) Left Hand Screw, 18" Diameter, 18" Pitch, 3/8" Thick, Sectional flight welded on 5 1/2" SCH80 Pipe, Bushed and 2-Bolt drilled for 2-15/16" Shafts. Over All Length 9'8". James Eagen Sons, Charter Machine Company, Fairfield, or Martin Sprocket & Gear Part #: 18SQ624-L or approved equal	89077000002	5	Each	\$ 3,013.56	FAIRFIELD	OBMS-18SQ624-L	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-27	(A & B SIDES ) 2-15/16" Hardened Coupling Shafts, James Eagen Sons, Charter Machine Company, Martin Sprocket & Gear or Fairfield, Martin Part #: CC6-H or approved equal	89077000003	30	Each	\$ 264.00	FAIRFIELD	OBM-CC6-H	8-10 weeks	GP JAGER
#1-28	(A & B SIDES) 18" x 2-15/16" Style 220 Bearing Hanger James Eagen Sons, Charter Machine Company, Martin Sprocket & Gear or Fairfield Martin Part #: 18CH2206 or approved equal	89077000004	24	Each	\$ 290.83	Martin Sprocket	18CH2206	2-3 weeks aro	Applied Industrial
#1-29	(A & B SIDES) 2" Hard Iron Hanger Bearing James Eagen Sons, Charter Machine Company or Martin Sprocket & Gear Martin Part #: CHB2204MHI or approved equal	89077000005	48	Each	\$ 49.97	Martin Sprocket	CHB2204MHI	2-3 weeks aro	Applied Industrial
#1-30	(A Side) Hanger Bearing 3" Bore; Martin Sintered Hard Iron Material for a Style 220, 226, 326, or 30 Hanger- Martin part # CHB2206MHI - or approved equal	89065000144	25	Each	\$ 128.25	Martin Sprocket	CHB2206MHI	2-3 weeks aro	Applied Industrial
#1-31	(B Side) Hanger Bearing 3.4375" Bore; Martin Sintered Hard Iron Material for a Style 220, 226, 326, or 30 Hanger- Martin part # CHB2207MHI or approved equal	89065000145	25	Each	\$ 224.37	Martin Sprocket	CHB2207MHI	2-3 weeks aro	Applied Industrial
#1-32	(B Side) End Shaft- 3 7/16" Shaft Diameter, 16 3/8" Length, for use with the bronze bearing and no seals, Martin part # CE7B- SAP or approved equal	89065000146	25	Each	\$ 258.48	Martin Speocket	CE7B	2-3 weeks aro	Applied Industrial
#1-33	(B Side) Coupling Shaft -3 7/16" X 17 1/2" Coupling shaft; Induction Hardened- RC45-50, Martin part # CC7-H or approved equal	89065000147	25	Each	\$ 505.94	Martin Sprocker	CC7-H	2-3 weeks aro	Applied Industrial
#1-34	(A & B SIDES)-3 x 16 5/8" Drive Shaft James Eagen Sons, Charter Machine Company or Martin Sprocket & Gear Martin Part #: 1CD6BB or approved equal	89077000006	12	Each	\$ 186.12	Martin Sprocket	1CD6BB	2-3 weeks aro	Applied Industrial

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-35	(A & B SIDES) 3" x 12 3/8" End Shaft James Eagen Sons, Charter Machine Company, Martin Sprocket and Gear Martin Part #: CE6BB-W or approved equal	89077000007	12	Each	\$ 130.35	Martin Sprocket	CE6BB-W	2-3 weeks aro	Applied Industrial
#1-36	(A SIDE) Y-17A, 2 7/16" dia. X 3'3" long Drive Extension Shaft cut for keyways 5/8" x5/8" Brewton, or approved equal	89077000008	10	Each	\$ 184.20	Brewton	2 7/16DIA. X 3'3"	4-5 weeks aro	Applied Industrial
#1-37	(A SIDE)145Y118-N Couping WT-53, bore 1 7/8"ks, 2 7/16"ks, Browning, or approved equal	89077000009	1	Each	\$ 594.00	FAIRFIELD	OBB-145Y118-N	8-10 weeks	GP JAGER
#1-38	H78-D Hub, 18 Teeth Cast Iron Rim Split Sprocket 15.02" PD x 15/16 Face, Max Offset 3", Max Bore 2-15/16", Fairfield, BREWTON H78-D Hub 18T CI Split or approved equal	89077000010	1	Each	\$ 1,174.80	FAIRFIELD	OBBIW-18T-H78-D	8-10 weeks	GP JAGER
#1-39	<b>Non-Metallic Collector Chain</b> 10' section NCS720s chain with F26 (6") attachment link attached As per the attached specifications Envirex, Allied Locke, Polychem, Siemens, Fairfield FFCBN720NA6TAA, Brandt NCS720-F226-20P or approved equal- Price must be submitted " per 10'section"	89065100001	50	10' section	\$ 223.21	FAIRFIELD	FFCBN720NA6TAA	8-10 weeks	GP JAGER
#1-40	<b>Non-Metallic Attachment Link</b> F26 (6") attachment link only for NCS720s chain As per the attached specifications Envirex, Allied Locke, Polychem, Siemens, Fairfield FFCBN720NA6T0A0, Brandt MFG NCS720-F226-POM or approved equal	89065100012	50	Each	\$ 23.57	FAIRFIELD	FFCBN720NA6T0A0	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-41	<b>Non-Metallic Collector Chain</b> 10' section NCS720s chain with F28 (8") attachment link attached As per the attached specifications Envirex, Allied Locke, Polychem, Siemens, Fairfield FFCBN720NA8TAAA, Brandt MFG NCS720-F228-10-POM or approved equal, Price must be submitted " per 10'section"	89065100011	50	10' section	\$ 223.21	FAIRFIELD	FFCBN720NA8TAAA	8-10 weeks	GP JAGER
#1-42	<b>Non-Metallic Attachment Link</b> F28 (8") attachment link only for NCS720s chain, As per the attached specifications. Envirex, Allied Locke, Polychem, Siemens, Fairfield FFCBN70NA8T0A0, Brandt #NCS720-F228 or approved equal	89065100013	50	Each	\$ 23.57	FAIRFIELD	FFCBN70NA8T0A0	8-10 weeks	GP JAGER
#1-43	<b>Flights with Filler Blocks</b> <b>3" x 8" x 19' 4"</b> As per the attached specifications Envirex Sigma, FMC 492X191, Hitachi Maxco, US Filter Envirex Products V06-1842-1-1, Polychem, Fairfield FF382D2W2R1232 w/ (2) FSC1FBPO386H4537 or approved equal	89065100004	120	Each	\$ 195.76	FAIRFIELD	FF382D2W2R1232/ FSC1FBPO386H4537	8-10 weeks	GP JAGER
#1-44	<b>Flights with Filler Blocks</b> <b>3" x 8" x 14'</b> As per the attached specifications Envirex Sigma, FMC 492X191, US Filter Envirex Products V06-1842-2-1, Polychem, Fairfield FF382D2W2R1168 w/ (2) FSC1FBPO386H4537 or approved equal	89065100005	150	Each	\$ 145.86	FAIRFIELD	FF382D2W2R1168/ FSC1FBPO386H4537	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-45	<b>Flight Sigma with Filler Block 3” x 6” x 117”</b> As per the attached specifications Envirex Sigma, US Filter Envirex Products H426625-1-100, Polychem, Allied-Locke, Fairfield FF362D2W2R0117 w/ (2) FSC1FBPO364H4537 or approved equal	89065100010	150	Each	\$ 106.60	FAIRFIELD	FF362D2W2R0117/ FSC1FBPO364H4537	8-10 weeks	GP JAGER
#1-46	<b>Wear Shoes – Carry Shoes</b> As per the attached specifications Envirex, FMC 806X66-1, Allied Locke, Polychem, Guardian, Fairfield FSCICWSUH53550A, Brandt #CWS55 or approved equal	89065100003	50	Each	\$ 6.41	FAIRFIELD	FSCICWSUH53550A	8-10 weeks	GP JAGER
#1-47	<b>Wear Shoes – Return Shoes</b> As per the attached specifications Envirex, FMC 806X66-1, Allied Locke, Polychem, Fairfield FSCIRWUSUH453550B, Brandt RWS50 or approved equal	89065100008	100	Each	\$ 6.73	FAIRFIELD	FSCIRWUSUH453550B	8-10 weeks	GP JAGER
#1-48	<b>Turn Shaft Sprockets</b> As per the attached specifications. Sprocket shall be affixed by set screens machined through the hub of the sprocket. Envirex, Brewton Iron Works, Hitachi Maxco, Allied Locke, Connexus, Fairfield FB13SUU290000SC60, Brewton W4651CS or approved equal	89065100006	12	Each	\$ 699.60	FAIRFIELD	FB13SUU290000SC60	8-10 weeks	GP JAGER
#1-49	<b>Turn Shaft Sprockets</b> As per the attached specifications. Sprocket shall be free wheeling & restricted from lateral movement by use of collars Envirex, Brewton Iron Works, Hitachi Maxco, Allied Locke, Fairfield FB13SUU290000SC60, Brewton W4651CS or approved equal	89065100009	12	Each	\$ 699.60	FAIRFIELD	FB13SUU290000SC60	8-10 weeks	GP JAGER



LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-50	<b>Head Shaft Sprockets</b> As per the attached specifications Envirex, Brewton Iron Works, Allied Locke, Guardian, Fairfield FB19SCU29K00SC60 or approved equal	89065100007	8	Each	\$ 891.00	FAIRFIELD	FB19SCU29K00SC60	8-10 weeks	GP JAGER
#1-51	<b>Chain</b> Stainless steel with attachment link every 10 feet Hitachi-Maxco, FMC, Connexus, Fairfield FFCBF7153A83JAAA or approved equal <b>as per attached specifications, Price must be submitted "per foot"</b>	89065110001	100	Feet	\$ 37.62	FAIRFIELD	FFCBF7153A83JAAA	8-10 weeks	GP JAGER
#1-52	<b>Head Shaft</b> Length: 19'6", Size: 3 15/16" diameter, Hitachi-Maxco, FMC, Shafting CF 1018 Oil Spray and Paper, ALI, Connexus, Fairfield FSC1HSSLS1023439, SES or approved equal <b>as per attached specifications</b>	89065110002	4	Each	\$ 3,445.20	FAIRFIELD	FSC1HSSLS1023439	8-10 weeks	GP JAGER
#1-53	<b>Turn Shaft</b> Length: 19', Size: 3 7/16" diameter, Hitachi-Maxco, FMC, Shafting CF 1018 Oil Spray and Paper, ALI, Connexus, Fairfield FSC18SSL1022834, SES or approved equal as per attached specifications	89065110003	8	Each	\$ 3,072.00	SES	Shaft 3 7/16 x 19'	4-5 weeks aro	Applied Industrial
#1-54	<b>Wear Strips For Floor Rails &amp; Return Tracks</b> Size: 3" x 1/2", Hitachi-Maxco, FMC, ALI, Connexus, Fairfield FSCIFWUH5030H120 or approved equal <b>as per attached specifications. Price must be submitted "per foot"</b>	89065110004	100	Feet	\$ 5.60	FAIRFIELD	FSCIFWUH5030H120	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-55	<b>Turn Shaft Sprockets</b> 17 teeth min. Hitachi-Maxco, FMC, SAV715 17T, Brewton, Fairfield FB17SUU34000SC60 or approved equal <b>as per attached specifications</b>	89065110005	10	Each	\$ 673.20	FAIRFIELD	FB17SUU34000SC60	8-10 weeks	GP JAGER
#1-56	<b>Head Shaft Sprockets</b> 19 teeth min., Hitachi-Maxco, FMC, Guardian, Brewton, Fairfield FB19CU39K00SC60 or approved equal <b>as per attached specifications</b>	89065110006	6	Each	\$ 620.40	FAIRFIELD	FB19CU39K00SC60	8-10 weeks	GP JAGER
#1-57	<b>Drive Sprockets</b> 40 teeth min., Hitachi-Maxco, FMC, Brewton, Martin, Fairfield FA40SCU00K0BS060 or approved equal <b>as per attached specifications</b>	89065110007	4	Each	\$ 2,125.20	FAIRFIELD	FA40SCU00K0BS060	8-10 weeks	GP JAGER
#1-58	<b>Submerged Bearings - Head Shaft Bearings</b> Hitachi-Maxco, FMC, Brewton W3698, Connexus, Fairfield FSC1WBIBBSMD000 or approved equal <b>as per attached specifications</b>	89065110008	8	Each	\$ 912.12	FAIRFIELD	FSC1WBIBBSMD000	8-10 weeks	GP JAGER
#1-59	<b>Submerged Bearings - Turn Shaft Bearings</b> Hitachi-Maxco, FMC, Brewton W3694, Connexus, Guardian 3-1622-4, Fairfield FSC1WBIBBSMD000 or approved equal <b>as per attached specifications</b>	89065110009	12	Each	\$ 650.76	FAIRFIELD	FSC1WBIBBSMD000	8-10 weeks	GP JAGER
#1-60	<b>Non-Metallic Collars</b> Hitachi-Maxco, FMC, ALI UHMW, 2-1821-4 UHMW, Guardian, Connexus, Tri-State Bearings, Fairfield or approved equal <b>as per attached specifications</b>	89065110010	25	Each	\$ 84.48	FAIRFIELD	OBHM-2-1821-4	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-61	<b>Take-Up Bearing Assembly</b> Hitachi-Maxco, FMC, Brewton W3611, 3-1652-4, Guardian, Connexus, Fairfield FSCITBFSBB000000 or approved equal <b>as per attached specifications</b>	89065110011	8	Each	\$ 1,401.84	FAIRFIELD	FSCITBFSBB000000	8-10 weeks	GP JAGER
#1-62	<b>2 3/16 Dia x 2' 2" Lg. Jack Shaft, Material - #C-1045 as specified,</b> Viking, ALI, Connexus, Tri-State Bearings, Fairfield, Martin, SES or approved equal	89065100014	6	Each	\$ 170.67	SES	Shaft 2 3/16" x 2' 2"	4-5 weeks aro	Applied Industrial
#1-63	<b>2 3/16 Dia x 4' 3" Lg. Jack Shaft, Material - #C-1045 as specified,</b> Viking, ALI, Connexus, Tri-State Bearings, Martin Sprocket, SES or approved equal	89065100015	10	Each	\$ 341.33	SES	Shaft 2 3/16" x 4' 3"	4-5 weeks aro	Applied Industrial
#1-64	<b>Ductile Iron Style 2 Sliding Base Chain Tighteners Complete with 7T Cast Iron Chilled Rim Sprocket as specified,</b> Viking, Brewton, Connexus, Fairfield FSCICHTN787TCICI or approved equal	89065100016	6	Each	\$ 435.60	FAIRFIELD	OBM-2 3/16 - 51	8-10 weeks	GP JAGER
#1-65	<b>11T78 Jaw Clutch/Handwheel Sprocket Style-2, RH 2 3/16 Bore Cast Iron Chilled Rim as specified,</b> Viking, Brewton, Connexus, Fairfield FA11SCC21000000 or approved equal	89065100017	6	Each	\$ 1,306.80	FAIRFIELD	FA11SCC21000000	8-10 weeks	GP JAGER

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#1-66	13T78 Jaw Clutch/Handwheel Sprocket Style-2, LH 2 3/16 Bore Cast Iron Chilled Rim as specified, Viking, Brewton, Connexus, Fairfield FA13SCC21000000 or approved equal	89065100020	6	Each	\$ 1,306.80	FAIRFIELD	FA13SCC21000000	8-10 weeks	GP JAGER
<b>MANUFACTURER % DISCOUNTS- Discounts must include FOB destination prepaid and allowed.</b>									
#2-1	Manufacturer Discount off <b>MARTIN</b> brand for parts (including but not limited to shafts, bearings, couplings) related to sludge collection equipment, not specified above. Bidders shall be required to submit manufacturer parts current price list. A discount of 10% must be entered as .10	89065000148	100	% Discount	22%				Applied Industrial
#2-2	Manufacturer Discount off <b>FMC</b> brand for parts (including but not limited to shafts, bearings, couplings) related to sludge collection equipment, not specified above. Bidders shall be required to submit manufacturer parts current price list. A discount of 10% must be entered as .10	89065000149	100	% Discount	21%				Applied Industrial
#2-3	Manufacturer Discount off <b>Charter Machine Company</b> for parts (including but not limited to shafts, bearings, couplings) related to sludge collection equipment, not specified above. Bidders shall be required to submit manufacturer parts current price list. A discount of 10% must be entered as .10	89065	100	% Discount	NO BID				Applied Industrial

LINE NO.	DESCRIPTION	Item Number	EST. QTY.	UNIT	Unit Price	Manufacturer (Mandatory Field)	Product # (Mandatory Field)	Lead Time	VENDOR
#2-4	Manufacturer Discount off <b>James Eagon Sons CO</b> brand for parts (including but not limited to shafts, bearings, couplings) related to sludge collection equipment, not specified above. Bidders shall be required to submit manufacturer parts current price list. A discount of 10% must be entered as .10	89065000150	100	% Discount	20%	James Eagen			Eastern Industrial
#2-5	Manufacturer Discount off <b>Brewton</b> brand for parts (including but not limited to shafts, bearings, couplings) related to sludge collection equipment, not specified above. Bidders shall be required to submit manufacturer parts current price list. A discount of 10% must be entered as .10	89065000151	100	% Discount	20%	Brewton			Eastern Industrial

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement  
 Parts**

**RFB #: RFB-RC-2025-106**

## PURCHASES BY OTHER

### LOCAL GOVERNMENTS, SCHOOL DISTRICTS, AND NON-PROFIT AGENCIES

As per the New York State General Municipal Law, all political subdivisions of New York State are allowed to make purchases through the resulting contract(s). As per Rockland County Procurement Policy, Non-Profit Agencies approved to participate in New York State's Contract Extension Program are authorized to make purchases through the resulting contract(s).

1. The County of Rockland shall make all contract award information available to other political subdivisions and non-profit agencies through our website: [www.rcpurchasing.com](http://www.rcpurchasing.com)
2. Any other political subdivision or Rockland County non-profit agency will issue purchase orders directly to vendors within the specified contract period referencing the County's contract and shall be liable for any payments due on such purchase orders; and shall accept sole responsibility for any payment due.
3. All purchases shall be subject to audit and inspection by the other political subdivisions and Rockland County non-profit agencies for which the purchase was made.
4. No officer, board or agency of a county, town, village, or school district shall make any purchase through the County when bids have been received for such purchase by such officer, board or agency, unless such purchase may be made upon the same terms, conditions and specifications at a lower price through the County.
5. All Bidders shall be on notice that as a condition of the award of a County contract, the successful bidder shall accept the award of a similar contract with any other political subdivision in New York State and Rockland County non-profit agencies authorized to use New York State's contracts, if called upon to do so. A listing of approved Rockland County non-profit agencies is available on the Purchasing Division's website at [www.rcpurchasing.com](http://www.rcpurchasing.com). The County, however, will not be responsible for any debts incurred by the participants pursuant to this or any other agreement.
6. Necessary deviations from the County's specifications in the award of a participant contract, whether such deviations relate to quantities, or delivery points shall be resolved between the successful bidder and the other political subdivisions and Rockland County non-profit agencies.

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

## **SPECIFICATIONS**

**A Virtual Pre-Bid via Microsoft Teams will be hosted on **September 11, 2025** at **11:00am**.  
 To Participate select the link below.**

**Microsoft Teams Meeting Link:** [CLICK HERE TO JOIN MEETING](#)

**Meeting ID: 277 912 248 276 6**  
**Passcode: X9G6bT37**

## **SPECIFICATIONS**

### **1. SCOPE**

- 1.1. The purpose of this bid is to solicit suppliers to provide pricing for the purchase of specified replacement parts for the Rockland County Sewer District #1 primary and secondary settling tanks (A and B Sides) at the Rockland County Sewer District # 1 treatment plant.
- 1.2. This bid is for pricing only. All Prices submitted must be FOB Destination prepaid and allowed.
- 1.3. Quantities shown are estimates. Items purchased will depend on the requirements of the Rockland County Sewer District # 1.
- 1.4. Bidders must be authorized manufacturer resellers.
- 1.5. Suppliers must have knowledge of and experience in providing these parts or similar to other municipal agencies.
- 1.6. No refurbished or second hand parts will be accepted.
- 1.7. This equipment must have the ability to interconnect with the existing equipment. Bidder must guarantee interconnectability in writing with the bid.
- 1.8. Bidders are strongly encouraged to schedule a site visit as specified. .

### **2. PRICE ADJUSTMENT**

- 2.1. The County recognizes this product or service has a price component that may have a commodity with changing costs. The Contractor/Supplier may request a Price Adjustment no more frequently than once per 6-month period.
- 2.2. A Price Adjustment request must be made in writing and include the reason for the request, documentation supporting the request (ie, commodity increases), the current pricing, and the requested revised pricing.
- 2.3. The County will review the Price Adjustment request. If the Price Adjustment is deemed reasonable the Price Adjustment request will be accepted by written acknowledgement. If the request is not

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

accepted the County may entirely reject the request or may counter with revised pricing. In either case the County will provide a written explanation in support of the decision.

- 2.4. The Director of Purchasing may use available indexes (e.g. CPI or PPI) to determine if the requested Price Adjustment is reasonable. Typically, a Price Adjustment that exceeds 5% will not be approved unless very unusual and significant changes have occurred in the industry.

2.5.

In the event industry costs decline, the County shall have the right to receive, from the Contractor, a reasonable reduction in prices/pricing that reflect such cost changes in the industry. The County will make a written request to the Contractor for a Price Adjustment in writing with supporting documentation.

### **3. TARIFF ADJUSTMENTS DUE TO TARIFF CHANGES**

- 3.1. In the event of changes to import tariffs or duties imposed by the U.S. government on the goods covered under this contract, the contractor may request an adjustment to tariff rates from time of award to the applicable tariff rate at time of order. The following conditions apply:
- 3.1.1. Requested for adjustments must be submitted in writing and include official government documentation on the tariff change.
  - 3.1.2. The county reserves the right to accept negotiate or reject any proposed price modifications.
  - 3.1.3. The awarded supplier must provide documentation of the tariff rate/cost at time of order
  - 3.1.4. The awarded supplier must provide documentation for actual tariff amount paid at the time of the invoice submission.
  - 3.1.5. If tariffs are reduced or removed, the contractor must adjust pricing downward accordingly.

### **4. SITE VISIT**

- 4.1. A site visit is highly recommended but not required. Bidders must contact Jeff Kmetz at 845-364-6494 or [KmetzJ@co.rockland.ny.us](mailto:KmetzJ@co.rockland.ny.us) to schedule a site visit.
- 4.2. Site visits must be completed on or before **September 17, 2025**.
- 4.3. Bidders who have scheduled a site visit must check in at the RCSD#1, Administration Office located at 4 Route 340, Orangeburg, NY 10962.
- 4.4. Each bidder must inform himself fully of the conditions relating to the contract and is encouraged to visit the site.

### **5. REQUIREMENTS**

- 5.1. Items bid shall be Mfg. by FMC, Brewton, Charter Machine Company, James Eagen Sons Co., Brandts, Martin specified on the proposal pages or approved equal.



**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

## 6. INTERCONNECTABILITY

- 6.1. This equipment must have the ability to interconnect with the existing equipment. Bidder must guarantee interconnectability in writing with the bid. In addition, vendor must provide any required data within five business days of request from the Rockland County Sewer District # 1 authorized representative.

## 7. COMPATIBILITY

- 7.1. Equipment offered shall be compatible with the existing equipment/environment in the plant settling tanks without the use of adapters. Guarantee letter must be submitted with bid.

## 8. APPROVED EQUAL OR EQUIVALENT PRODUCTS

- 8.1. Bidders shall submit an item by item listing and explanation of any differences between their product specifications and performance and the listed bid specifications. Product and service warranties must be included with bid.
- 8.2. If bidders submit or bid for equivalent or approved equal products, they must submit manufacturer's product description and specifications. Bidder shall also include a side by side comparison of the offered product to the specified product.
- 8.3. Items requiring adapters will not be acceptable. Bidder must provide a list of 5 installations where items bid are being used with the same type of equipment that is being utilized by the Rockland County Sewer District # 1. The equipment shall have been in use for a minimum of three years. References need to include location, contact email and telephone number of each installation. See Certification of Experience Form.
- 8.4. Bidder must be able to demonstrate within one week after notice and guarantee in writing that the item bid is interconnectable with existing equipment.

## 9. BRAND NAME

- 9.1. The use of a brand name is for the purpose of describing a standard of quality, performance and characteristics desired and is not intended to limit or restrict competition.

## 10. DELIVERIES

- 10.1. All parts must be delivered Monday – Friday, excluding holidays, between the hours of 8 AM – 2 PM.

## 11. DETAILED SPECIFICATIONS

### 11.1. SPROCKETS

- 11.1.1. Sprockets are to be deep chilled with a Birnell hardness of 360 min. and 3/16" minimum depth chill.

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

**11.2. SPECIFICATIONS FOR NON-METALLIC COLLECTOR CHAIN AND ATTACHMENT LINKS ITEMS 39-42**

11.2.1. All collector flight chain furnished by the Contractor must meet the following specifications:

- 11.2.1.1. Chains shall be 6" pitch type 720, curved side bar with an average weight of 1.3 to 1.4 lbs. per foot. Side bars shall be curved to a 10" radius. The chain shall have a catalog working load of not less than 2,600 lbs. based upon both strength and wear considerations.
- 11.2.1.2. Lengths and attachments shall be manufactured of reinforced polyester alloy with barrel and side bars integrally molded to insure squareness of the links. Connecting pins of glass reinforced polyester alloy or fiberglass fortified acetal shall have a T-head feature to prevent pin rotation, and shall be held in place without the need for spring clips, cotters or similar devices. The pins shall be pressed into the link side bars to exclude abrasives. Rigid attachments shall extend the full depth of the flight and shall be designed to push the flight to minimize the loading on the flight attachment bolts. Attachments are to be spaced at 10 foot centers.
- 11.2.1.3. The chain barrel shall have a diameter along its full working length, which allows proper engagement, with a 1" maximum face width of a 720 sprocket.
- 11.2.1.4. Each link must have a 6" pitch with .941" diameter pins.
- 11.2.1.5. Chain lengths shall be proof tested at a load of 5,000 lbs. Proof loads must not cause damage or distortion to the chain.
- 11.2.1.6. Copies of chain tests performed on identical chain must be submitted to document compliance with the specifications.

**11.2.2. Quality Control**

- 11.2.2.1. The chain manufacturer must have an approved SPC System in effect and in use from raw material inspection through and including chain test. To insure in process control, the following tests shall be run at the appropriate time in the manufacturing cycle:
  - 11.2.2.1.1. Ultimate strength of single links and pins - Two links and pins shall be pull tested for every 125 pieces molded. This shall be continuous throughout the molding operation. The loading shall be averaged to verify that the ultimate strength is not less than 6,300 lbs.
  - 11.2.2.1.2. Qualification ultimate strength testing of assembled chain - Six pitch sample strands from each lot of molded links and pins shall be qualified prior to chain assembly. Qualification testing shall consist of ultimate strength test performed by the chain manufacturer. The ultimate strength of the sample strands shall exceed 6,300 lbs. with an elongation not to exceed 3 percent.
  - 11.2.2.1.3. Proof loading of assembled ten-foot (20 pitches) chain strands - Every assembled ten-foot strand of chain shall be proof loaded to 5,000 lbs. prior to shipping.
  - 11.2.2.1.4. Chain strands shall be shipped in 10-foot sections and shall be checked for matching per ANSIB 29.21M - 1981. Chain to be matched within .190".

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

- 11.2.2.1.5. Length specifications - Assembled 20 - Link strands of 6" pitch chain under a 130-pound measuring load shall not be less than 120.0 inches and not greater than 120.75 inches.
- 11.2.2.1.6. Camber specifications - Chain camber shall comply with requirements of ANSIB 29.21M - 1981. Chain to camber a minimum of 1 inch in each direction and to be equal to each other within 1 1/2 inch.
- 11.2.2.1.7. Twist specifications - Chain twist shall comply with requirements of ANSIB 29.21M - 1981. Assembled 10-foot strands shall twist a minimum of 10° in each direction and be equal to each other within 15°.
- 11.2.2.1.8. Certified test data on the above shall be submitted to the owner for their review and approval.

### 11.3. SPECIFICATIONS FOR FLIGHTS ITEMS 43 AND 44

- 11.3.1. The fiberglass flights shall be 3" x 8" nominal size, essentially rectangular in cross section, with the front having a transverse concave indentation to provide structural support, and a transverse gap in the back to allow circulation of water through the member to render it non-buoyant. The member shall have a Moment of Inertia of not less than 2.01 about its minor axis. The flight shall be of pultruded isothalic polyester composite construction with an average fiberglass content of 45 percent to ensure total encapsulation of the glass fibers to prevent wicking. The use of extenders in the resin is prohibited.
- 11.3.2. Maximum water absorption shall be no greater than 0.5% in accordance with ASTM D-570. The flight section shall include a scraper lip on the leading edge of the flight to optimize cleaning of the tank floor. Polypropylene filler books shall be furnished to allow the flight to be securely bolted to the chain attachment. The blocks shall provide an interference fit with the flight to maintain proper positioning during assembly. Flight shall be accurately drilled and notched at the factory and banded together for shipment.

### 11.4. SPECIFICATIONS FOR FLIGHTS ITEM 45

- 11.4.1. Flights shall be 3" x 6" nominal size fiberglass construction, essentially rectangular in cross section, with the front having a transverse concave indentation to provide structural support, and a transverse gap in the back to allow circulation of water through the member to render it non-buoyant. The member shall have a Moment of Inertia of not less than \* in.<sup>4</sup> about its minor axis. The flight shall be of pultruded isothalic polyester composite construction with a minimum fiberglass content of 50 % but no greater than 60%, to ensure member strength and to insure total encapsulation of the glass fibers to prevent wicking. The use of extenders in the resin is prohibited.
- 11.4.2. Maximum water absorption shall be no greater than 0.6% after immersion for 48 hrs. at 73.4° F (23° C) in accordance with ASTM D-570. The flight section shall include a scraper lip on the leading edge of the flight to optimize cleaning of the tank floor. Polypropylene filler blocks shall be furnished to allow the flight to be securely bolted to the chain attachment. The blocks shall

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

provide an interference fit with the flight to maintain proper positioning during assembly. Flight spacing shall be approximately 10 ft. for longitudinal collectors (and 5 ft. for cross collectors). Flight shall be accurately drilled and notched at the factory and banded together for shipment.

11.4.2.1. a\* Moment of inertia for a 6" sigma flight = 1.6.

#### **11.5. SPECIFICATIONS FOR UHMW WEAR SHOES ITEMS 46 AND 47**

11.5.1. Each flight shall be provided with 1/2" thick UHMW wear shoes designed to run on the return track and floor rails respectively. Material shall be all virgin as defined by ASTM D 4020-81. Wear shoes shall be made from a powder having a molecular weight exceeding four million and intrinsic viscosity greater than 24. Finished wear shoes shall have a relative abrasion resistance of 12. Water absorption after 24 hours immersion per ASTM D570 shall be nil.

11.5.2. Maximum water absorption shall be no greater than 0.6% after immersion for 48 hrs. at 73.4<sup>0</sup> F (23<sup>0</sup> C) in accordance with ASTM D-570. The flight section shall include a scraper lip on the leading edge of the flight to optimize cleaning of the tank floor. Polypropylene filler blocks shall be furnished to allow the flight to be securely bolted to the chain attachment. The blocks shall provide an interference fit with the flight to maintain proper positioning during assembly. Flight spacing shall be approximately 10 ft. for longitudinal collectors (and 5 ft. for cross collectors). Flight shall be accurately drilled and notched at the factory and banded together for shipment.

11.5.2.1.a \* Moment of inertia for a 6" sigma flight = 1.6.

#### **11.6. SPECIFICATIONS FOR SPROCKETS ITEMS 48,49 AND 50**

11.6.1. Turn Shaft Sprockets - Sprockets for the collector chains shall be machined totally of UHMW-PE, virgin material having a hardness of not less than Rockwell R56, having a tensile of no less than 6,400 PSI based on ASTM D638 standards, and a water absorption rate not to exceed 1.3 percent at saturation in accordance with ASTM D570. The sprockets shall be of split construction. The sprockets halves shall be assembled on the shafting with stainless steel bolts through the hub which exert compressive force around the full periphery of the hub. All sprockets shall have a chain saver rim retained into the body for the full 360<sup>0</sup> of the sprocket. Chain saver rims utilizing bolts, wraps, or fasteners to retain the chain saver flange to the sprocket will not be accepted. One shaft sprocket per turn shaft shall be affixed by set screws machined through the hub of the sprockets. The other sprocket shall be freewheeling, restricted from lateral movement by use of collars.

11.6.1.1. Sprocket size: Min. Pitch Diameter: 12.89", Min. Number of teeth: 13.

11.6.1.2. Bore Size: 2 15/16".

11.6.2. Head Shaft Sprockets - Sprockets for the head shaft shall utilize a combination design with a cast iron body, split with keyway and set screw. The head shaft sprockets shall have the keyway machined into the hub in such a way as to restrict lateral movement of the key. The teeth shall be replaceable and machined out of UHMW-PE as described above. The cast iron hubs shall be shop painted by the manufacturer with two coats of an approved corrosion resistant paint.

11.6.2.1. Sprocket size: Min. Pitch Diameter: 18.45", Min. Number of teeth: 19.

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

11.6.2.2. Bore Size: 2 15/16".

### **11.7. SPECIFICATIONS FOR ITEM 51 – CHAIN**

- 11.7.1. The collector chain shall be type 715 stainless steel 403 grade as manufactured by Hitachi-Maxco Ltd., FMC, or approved equal.
- 11.7.2. Each link shall have a 6.00 inch pitch with 9/16" diameter pin. The weight of the chain including an F228 attachment in 10 foot long strands shall not be less than 3.9 pounds/foot.
- 11.7.3. The steel sidebars shall be 15/64" thick x 1 57/64" maximum height of type 403 stainless steel. The sidebar shall be annealed and treated for stress relieved stabilized microstructure. The sidebar shall be of the curvature to accepting onto chain saver type sprockets.
- 11.7.4. All barrels shall be made of type 403 stainless steel. The barrels shall have a hardness range of 35-45 Rockwell C, and shall have adequate toughness to withstand normal abuse in handling installation and service. Barrel diameter shall be 1.024 inches.
- 11.7.5. The chain barrel shall have a diameter along its full working length which allows proper engagement with a 1 inch maximum face of sprocket.
- 11.7.6. All chain pins shall be made of type 403 stainless steel. Heat treated to a hardness of 35-45 Rockwell C, all pins shall have Type 304 stainless steel J cotters.
- 11.7.7. The chain shall be furnished in accordance with good chain manufacturing practice, including link squareness and removal of burrs.
- 11.7.8. Chain shall be furnished with a black protective finish. Finish is to protect chain during shipment and storage prior to use.

### **11.8. SPECIFICATIONS FOR ITEMS 52 AND 53 SHAFTS**

- 11.8.1. Shafts shall be cold rolled steel, straight and true, continuous between bearings. Shafts shall be shipped stripped and painted with 3 mills of suitable coating. Set collars for each turn shaft shall be supplied.

<u>SHAFT</u>	<u>DIAMETER, INCHES</u>
ITEM #48 Head Turn	3 15/16"
ITEM #49 Turn Shaft	3 7/16"

- 11.8.3. Item #48 is 19 feet and 6 inches in length and has three keyways.
- 11.8.4. Item #49 is 19 feet in length.
- 11.8.5. Items #48 and #49 shall be painted with 3 mils of suitable coating – Houghtons #344 Rust Preventative or approved equal.

### **11.9. SPECIFICATIONS FOR ITEM 54 – WEAR STRIPS FOR FLOOR RAILS AND RETURN TRACKS**

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

- 11.9.1. UHMW-Polyethylene wear strips, 1/2 inch thick by 3 inches wide, shall be provided and attached to the existing steel floor rails and return tracks. Each strip shall include one anchoring hole and not less than two slotted holes to accommodate the 316 stainless steel weld washers used to secure the wear strips to the steel rails and tracks. Ends of the strips shall be beveled to allow a smooth transition from section to section.

**11.10. SPECIFICATIONS FOR ITEM 55 – TURN SHAFT SPROCKETS**

- 11.10.1. Sprockets for the collector chains shall be machined totally of UHMW-PE, virgin material having a hardness of not less than Rockwell R56, having a tensile of no less than 6,400 PSI based on ASTM D638 standards, and a water absorption rate not to exceed 1.3 percent at saturation in accordance with ASTM D570. The sprockets shall be of split construction and shall have a tooth profile compatible with stainless steel chains.

The sprocket halves shall be assembled on the shafting with stainless steel bolts through the hub which exert compressive force around the full periphery of the hub. All sprockets shall have a chain saver rim retained into the body for the full 360 degrees of the sprocket. Chain saver rims utilizing bolts, wraps, or fasteners to retain the chain saver flange to the sprocket will not be accepted. One turnshaft sprocket per turn shaft shall be affixed by set screws machined through the hub of the sprockets. The other sprocket shall be freewheeling, restricted from lateral movement by use of collars.

- 11.10.2. Sprocket Size: Min. Pitch - 16.60, Min. # of Teeth – 17

**11.11. SPECIFICATIONS FOR ITEM 56 – HEAD SHAFT SPROCKETS**

- 11.11.1. Sprockets for the head shaft shall utilize a combination design with a cast iron body, split with keyway and set screw. The head shaft sprockets shall have the keyway machined into the hub in such a way as to restrict lateral movement of the key. The teeth shall be replaceable and machined out of UHMW as described above. The cast iron hubs shall be

Shop painted by the manufacturer with two coats of an approved corrosion resistant paint.

- 11.11.2. Sprocket Size: Min. Pitch - 18.45, Min. # of Teeth – 19

**11.12. SPECIFICATIONS FOR ITEM 57 – DRIVE SPROCKET**

- 11.12.1. The drive sprocket shall be designed to operate on H78 drive chain. The sprocket shall be of split construction. Hubs shall be made of cast iron, conforming to ASTM A48, and be of the offset design. The drive sprocket shall have not less than 40 teeth. Sprocket teeth shall be manufactured of UHMW. UHMW material shall be made from a powder having a molecular weight exceeding four million and intrinsic viscosity greater than 24 and have a relative abrasion resistance of 12. Water absorption after twenty four (24) hours immersion per ASTM D570 shall be nil. Teeth

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
 BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
 TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement Parts**

**RFB #: RFB-RC-2025-106**

shall be furnished in replaceable segments and attached to the hubs with type 18-8 stainless steel fasteners.

**11.13. SPECIFICATIONS FOR ITEMS 58 AND 59 – SUBMERGED BEARINGS**

- 11.13.1 All underwater bearings shall be babbitted and of the water lubricated Peak Cap self-aligning type specially designed to prevent accumulation of settled solids on their surfaces. Bearings shall be two piece to permit easy removal of the shaft without removing the bearing bracket from the wall. These bearings shall be bolted directly to the concrete wall in a manner which will permit their easy adjustment. The bearings shall be equipped with grease fittings for lubrication when the tanks are dewatered.

**11.14. SPECIFICATIONS FOR ITEM 60 – NON-METALLIC COLLARS**

- 11.14.1. All collars furnished for sludge collector shafting shall be manufactured of polyurethane. The collars shall be of split construction mounted with 3/8" diameter stainless steel hardware. The collars shall have male-female locators to assure proper alignment.

**11.15. SPECIFICATIONS FOR ITEM 61 – TAKE-UP BEARING ASSEMBLY**

- 11.15.1. Take-up assemblies shall be provided for one shaft of each longitudinal collector; shall provide not less than 12" horizontal travel; shall be of the cantilever fabricated steel design with bronze take-up screws, so designed that no recesses in the concrete are required to maintain clearances.

11.16. **Item #62** - 2 3/16 Dia x 2' 2" Lg. Jack Shaft, Material - #C-1045

11.17. **Item #63** - 2 3/16 Dia x 4' 3" Lg. Jack Shaft, Material - #C-1045

11.18. **Item #64**- Ductile Iron Style 2 Sliding Base Chain Tighteners Complete with 7T Cast Iron Chilled Rim Sprocket

11.19. **Item #65** - 11T78 Jaw Clutch/Handwheel Sprocket Style-2, RH 2 3/16 Bore Cast Iron Chilled Rim

11.20. **Item #66** - 13T78 Jaw Clutch/Handwheel Sprocket Style-2, LH 2 3/16 Bore Cast Iron Chilled Rim

**12. MANUFACTURERS DISCOUNTS ( Lines 2-1 to 2-5)**

- 12.1. Bidders may submit % discount off Manufacturers List Price on Manufacturers Parts numbers not specified. Bidders who do not provide Manufacturers current price list may be deemed non-responsive.
- 12.2. Price list shall list all parts including, but not limited to, bearings, shafts, sprockets, drives related to the
- 12.3. % discounts submitted must account for FOB Destination prepaid and allowed, in the discount.
- 12.4. No shipping costs will be paid by the county

**COUNTY OF ROCKLAND - DGS-PURCHASING**  
BLDG. A., 6TH FLOOR, 50 SANATORIUM RD, POMONA, NY 10970  
TELEPHONE: 845-364-3820 / TELEFAX: 845-364-3809

**TITLE: Sludge Collection Equipment- Replacement  
Parts**

**RFB #: RFB-RC-2025-106**

- 12.5. The ordering department may request a quote for the product and quantities needed. All quotes provided must include the Manuf. List price- Discount- Net Price per item and product lead time with quote.
- 12.6. The county must be able to verify that price offered meets the percent discount awarded on the contract at time of order.
- 12.7. Once awarded a contract, the percentage discount offered to authorized users, may be increased at the contractor's option, based on individual orders, but in no instance shall the discount be lower than the awarded discount for the duration of the contract.
- 12.8. All price list updates must be approved, in writing, by the Purchasing Director before they become effective.
- 12.9. Price increases will not be approved if requested upon receipt of an order.

### **13. AWARD**

- 13.1. Award shall be made on a line-by-line basis to the lowest responsive responsible bidder(s) meeting the stated requirements.
- 13.2. Quantities listed are estimates. Actual quantities may be more or less than the estimated amounts. Items purchased will depend on the requirements of the Rockland County Sewer District # 1.
- 13.3. In an effort to expedite the award of this contract and to immediately process a Purchase Order, the County is requesting all bidders submit the required Workman's Compensation Certificate, NYS Disability Certificate and Certificate of Liability with their bid submission, however, the apparent low bidder shall have minimum of five days after notification to submit the required documentation.